

Photos of Cilaki 2x4MW HEP in Indonesia
Project Information

Type	Layout	Rated Head (m)	Rated Discharge (m ³ /s)	Unit Qty. & Capacity (MW)	Voltage (KV)	Inlet Valve Type & Diameter (mm)	Date of Completion	Client
Francis	Horizontal	103	2 x 4.1	2 x 4	6.3 - 20	HBFV 1100	2016.01	PT. Inti Cipta Energi

Turbine Model No.	Generator Model No.	Rated Speed (rpm)	Runaway Speed (rpm)	Others
HLA575C-WJ-93	SFW3731-8/1730	750	1333	F, 50Hz, PF:0.8 Lagging, SCR Excitation System















